



Drinking Water Quality / Drinkwaterkwaliteit

October 2025 - May 2026

Description of test Beskrywing van toets	Unit Eenheid	Standard Standaard as per SANS 0241	Average test results for potable water test samples at: Gemiddelde toetsresultate van drinkwatermonsters vir:								
			Buffelsrivier (Rooi Els, Pringlebaai, en Bettysbaai)	Kleinmond	Hermanus	Stanford	Gansbaai	De Kelders	Pearly Beach	Baardskeedersbos	Buffelsjagsbaai
pH	pH units	≥ 5 to ≤ 9,7	5,9	6,7	7,7	7,5	6,3	7,0	7,0	8,9	7,5
Electrical conductivity Elektriese geleidingsvermoë	mS/m	≤ 170	13,8	13,2	48,5	37	67	34	54	64	159
Turbidity Troebelheid	NTU	≤ 1	0,7	0,3	0,7	0,4	0,4	0,3	0,4	0,4	0,3
Colour Kleur	mg/l as Pt-Co	≤ 15	10	10	10	10	10	10	10	10	10
Iron Yster	µg/l as Fe	≤ 300	20	20	20	-	20	-	29	31	20
Manganese Mangaan	µg/l as Mn	≤ 100	-	-	20	-	-	-	-	25	-
Aluminium Aluminium	µg/l as Al	≤ 300	105	31,4	153	-	54	-	55	-	-
E.coli E.coli	Count/100ml	0	0	0	0	0	0	0	0	0	0
Total Hardness Totale Hardheid	mg/l as CaCO ₃	-	18	20	46	120	91	76	71	27	342