



GEHALTE VAN BEHANDELDE RIOOLWATER-UITVLOEISEL WASTE WATER EFFLUENT QUALITY AT MUNICIPAL SCHEMES UMGANGATHO WONGCOLISEKO LWAMANZI KWIZIKIM ZIKAMASIPALA

OKTOBER 2017 - MAART 2018 | OCTOBER 2017 - MARCH 2018 | OKTHOBHA 2017 - MATSHI 2018

DESCRIPTION OF TEST BESKRYWING VAN TOETS	UNIT EENHEID	DWS GENERAL AUTHORI- SATION STANDARDS*	Average test results for final effluent test samples at: Gemiddelde toetsresultate van finale uitvloeiselmonsters vir:					Hermanus Permit Authori- sation Standards
			Gansbaai	Hawston	Stanford	Kleinmond	Hermanus	
pH	(pH)	5.5 - 9.5	6.8	7.8	7.5	7.6	7.5	5.5-9.5
ELECTRICAL CONDUCTIVITY ELEKRIESE GELEIDINGSVERMOË	(mS/m)	150	136	151	135	117	207	5000
FAECAL COLIFORM BACTERIA FEKALE KOLIFORME BAKTERIE	(count/100mℓ)	1000	34	111	60	22	93	1000
CHEMICAL OXYGEN DEMAND CHEMIESE SUURSTOFVRAAG	(mg/ℓ)	75 Max	48	64	56	57	51	75 Max
AMMONIA NITROGEN AMMONIAKSTIKSTOF	(mg/ℓ as N)	6 Max	0.3	2	2	21	4	7 Max
NITRATE NITROGEN • NITRAATSTIKSTOF	(mg/ℓ as N)	15 Max	10	1	14	3	2	17 Max
NITRITE NITROGEN • NITRIETSTIKSTOF	(mg/ℓ as N)	15 Max	0.2	0.2	0.3	0.2	0.2	17 Max
TOTAL SUSPENDED SOLIDS TOTALE SWEWENDE VASTE STOWWE	(mg/ℓ)	25 Max	6	10	10	14	8	25 Max
ORTHO-PHOSPHATE • ORTO-FOSFAAT	(mg/ℓ as P)	10 Max	5	3	7	6	4	10 Max

*Applicable to all WWTW's except Hermanus

Die Departement van Water & Sanitasie (DWS) beveel aan dat munisipaliteite van tyd tot tyd inligting ten opsigte van die gehalte van die uitvloeisel van hul rioolsuiweringswerke publiseer.

Die gehalte van die finale rioolwerke-uitvloeisel word gemeet teen standarde wat deur DWS gestel word, welke standarde as of Algemene Standarde of Spesiale Standarde geklassifiseer word.

Die tabel hierbo illustreer die gemiddelde metings by Munisipaliteit Overstrand se vyf suiweringsaanlegte teenoor parameters wat vir die gehalte van uitvloeisel gestel word in oor die afgelope twaalf maande, vergeleke met die DWS se Standarde. Monsters word op 'n maandelikse basis vir ontleding deur geakkrediteerde laboratoria geneem.

In Munisipaliteit Overstrand voldoen die gehalte van die finale uitvloeisel van vuilwater in 96% van die gevalle.

In gevalle waar die toets resultate van die finale uitvloeiselmonster nie voldoen aan die standaard nie, word daar regstellings by die werke gedoen. Die afloopwater word dan weer getoets om te verseker dat alle parameters aan die standaard voldoen.

The Department of Water & Sanitation (DWS) recommends that municipalities periodically publish information on the quality of drinking water supplied to consumers as well as final waste water effluent quality results.

Waste water effluent quality is measured against standards as set by DWS, which are classified as either General Standards, or Special Standards.

The table for waste water effluent quality illustrates Overstrand Municipality's average effluent quality parameter measurements at the 5 treatment plants over the past twelve months. Samples are taken for analysis on a monthly basis by accredited laboratories.

Overstrand Municipality's final waste water effluent quality complies 96% overall.

When the final effluent quality does not comply with the General Standards, corrections are made at the treatment works. The final effluent quality is then re-tested against the General Standards for compliance.

ISebe leZamanzi (DWA) lindulula ukuba amaxesha ngamaxesha oomasipala mabazazise iinkcukacha zomgangatho wamanzi okusela ababonelela ngawo abantu nomgangatho wamanzi amdaka.

Amanzi amdaka axilongwa ngokwamanqanaba abekwe nguDWA, achazwa njenge-General Standards, okanye i-Special Standards.

Ittheyibhuli yokunyangwa kwamanzi amdaka ibonakalisa umndilili womgangatho wamanzi nezikhokelo kumaziko ama-5 kaMasipala weOverstrand kwiinyanga eziluhlumi linambini. Kuthatyathwa amanzana athunyelwe kumaziko okuxilonga amanzi abhalisiweyo.

Umgangatho wamanzi kaMasipala weOverstrand uhambelana neGeneral Standard kuma-96% omndilili wemilinganiselo.

Xa amanzi okugqibela engahambelani neGeneral Standards, kulungiswa kumaziko onyango-manzi. Aphinda axilongwe kujongwe ukuba ayahambelana na neGeneral Standards. Ittheyibhuli yala manzi iquka onke amanzana axilongiweyo, kuquka nalawo ebengahambelanga neGeneral Standards.

Vertel jou vriende: Overstrand bied soveel meer • Tell your friends: Overstrand offers so much more
Xeleta izihlobo: Zakho ukuba iOverstrand ikunika kangangoko inako